

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1004:105 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Air Products and Controls Inc., 1749 East Highwood, Pontiac MI 48340
Contact: Bill Ryan (248) 332-3900

DESIGN: Models RWH-N, RWH-P, RWL-N, RWL-P, RWX-N, RWX-P, RWJ-N, RWJ-P, RWF-N, RWF-P and *SL-2000-N and *SL-2000-P duct smoke detectors. All units are four-wire duct detectors. Suffix -N indicates the unit employs an ionization smoke detector head. Suffix -P indicates the unit employs a photoelectric smoke detector head.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VAC, 24 VDC, 115 VAC or 230 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as duct detectors for use with separately listed compatible fire alarm control units when installed in HVAC systems with air velocity between 500 and 4000 ft./min.

*Rev. 11-12-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager